

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : KNL/06237/12/2023 / Private	Sample Details	Date & Time
Sender : MATA RAM PIARI D.A.V.PUBLIC SCHOOL26774	Collected By	
Location : , V.P.O NIGDHU,KNL	Collection Date	06/12/2023 at 14:17
Sample Description : Drinking Water	Received at lab	06/12/2023 at 14:35
Latitude / Longitude : 76.976922 / 29.689282	Analysis Start Date	06/12/2023
	Analysis End Date	06/12/2023
	Sample Quantity	1000ML

Test Result (As Per BIS 10500 :2012)


S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	370	500 mg/lit.	2000 mg/lit.	IS 3025 (Part-16) : 2023
2	Total Hardness as CaCo3	210	200 mg/lit.	600 mg/lit.	IS 3025 (Part-21) : 2009 (RA 2023)
3	Calcium as Ca	44	75 mg/lit.	200 mg/lit.	IS 3025 (Part-40) : 1991 (RA 2023)
4	Magnesium as Mg	24	30 mg/lit.	100 mg/lit.	IS 3025 (Part-46) : 2023
5	Iron as Fe	0.01	1.0 mg/lit.	1.0 mg/lit.	USEPA-8008:2017
6	Chloride as Cl	55	250 mg/lit.	1000 mg/lit.	IS 3025 (Part-32) : 1988 (RA 2019)
7	Sulphate as So4	25	200 mg/lit.	400 mg/lit.	USEPA-8051:2017
8	Fluoride as F	0.410	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C
9	Nitrate as No3	3.1	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D
10	pH @ 25°C	7.39	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 2022
11	Total Alkalinity	230	200 mg/lit.	600 mg/lit.	IS 3025 (Part-23) : 1986 (RA 2019)
12	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part 4): 2021
13	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) :1984 (RA 2018)
14	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :1984 (RA 2022)
15	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2022)

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by: *Joginder Singh*



AMIT KUMAR, CHIEF CHEMIST 06/12/23
STATE WATER TESTING LABORATORY, KARNAL
email: chiefchemist.hr@phedharyana.gov.in