

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20182019/27059

DATE: 19/12/2018

**From :**

**The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.**

**To :**

**G III STORIED BUILDING DAV MODEL SCHOOL  
G III STORIED BUILDING DAV MODEL SCHOOL.  
DR.B.C.ROY ROAD KSTP KANYAPUR LINK ROAD ASANSOL PLOT  
NO.D/INS/12.RS.PLOT.NO.832(P),833,834(P),838(P),839(P),860(P)TO  
862(P),85/1388(P),860/1525(P) & 838/1564 MOUZA.SHITLA JL NO.21 DIST.PASCHIM  
BURDWAN.713305  
Asansol F.S., Asansol PS (S),  
Paschim Bardhaman - 713305 .**

**Sub :Fire Safety Certificate for the occupancy of an existing construction of G + 3  
storied building under group Educational at the premises no.- G III STORIED  
BUILDING DAV MODEL SCHOOL.**

**DR.B.C.ROY ROAD KSTP KANYAPUR LINK ROAD ASANSOL PLOT  
NO.D/INS/12.RS.PLOT.NO.832(P),833,834(P),838(P),839(P),860(P)TO  
862(P),85/1388(P),860/1525(P) & 838/1564 MOUZA.SHITLA JL NO.21 DIST.PASCHIM  
BURDWAN.PIN-713305, Asansol PS (S), Paschim Bardhaman - 713305**

This is in reference to your Application No. IND/WB/FES/20182019/27059, dated 19/12/2018, regarding the Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.- G III STORIED BUILDING DAV MODEL SCHOOL.

DR.B.C.ROY ROAD KSTP KANYAPUR LINK ROAD ASANSOL PLOT  
NO.D/INS/12.RS.PLOT.NO.832(P),833,834(P),838(P),839(P),860(P)TO  
862(P),85/1388(P),860/1525(P) & 838/1564 MOUZA.SHITLA JL NO.21 DIST.PASCHIM  
BURDWAN.PIN-713305, Asansol PS (S), Paschim Bardhaman - 713305.

The performance of the Fire Fighting System as incorporated in the buildings were tested at


  
Headmaster  
DAV MODEL SCHOOL  
KSTP B.C Roy Road Asansol

  
Manager LMC  
DAV MODEL SCHOOL KSTP, Asansol, WB

random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. 1. Minimum 2nos ABC (6kgs) and 1 Carbondioxide (4.5kgs) , 1no Water type(9lts.) Fire extinguisher shall be kept at each floor as well as Manual Call point & Public address system shall be arranged within three months.
  2. One additional Stair case shall be constructed as far as practicable from the existing stair case within three months.
  3. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
  4. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
  5. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
  6. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
  7. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
  8. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
  9. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
  10. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
  11. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
  12. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
  13. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
  14. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
  15. Floor numbers and directional sign of escape route shall be displayed prominently.
- Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the FSC shall be treated


  
Headmaster  
DAV MODEL SCHOOL  
KSTP B.C Roy Road Asansol

  
Manager EMC  
DAV MODEL SCHOOL KSTP, Asansol, WB

cancelled.

**Divisional Fire Officer  
West Bengal Fire & Emergency Services**

Signature valid  
Digitally signed by ASHIM  
SARKAR  
Date: 2018.12.19 12:37:43 IST

  
Headmaster  
DAV MODEL SCHOOL  
KSTP B.C Roy Road Asansol

  
Manager LMC  
DAV MODEL SCHOOL KSTP Asansol Wb